

Challenges of Renewable Energy Integration

21 January 2026

500 GW Non-fossil fuel power generation capacity by **2030**


Share of energy requirement to be met by renewable energy by **2030** **50%**

3 billion tonnes Reduction in total projected carbon emissions by **2030**


Reduction in carbon intensity of its economy by **2030** **45%**

Net Zero Targeted emissions to be achieved by **2070**

India's VRE capacity is expected to increase over 212% in next 7 years



RE and BESS costs declined rapidly over the last 10 years




The cost decline is more pronounced in last three years


Six phases of variable renewable energy integration, IEA

- 01 VRE has no significant impact at the system level
- 02 VRE has a minor to moderate impact on the system
- 03 VRE determines the operation pattern of the power system
- 04 VRE meets almost all demand at times
- 05 Significant volumes of surplus VRE across the year
- 06 Secure electricity supply almost exclusively from VRE

Widening belly of the “Duck Curve”




Maximum demand met by RE generation at a particular instance (Top 10 states)




Key Challenges in VRE Integration

All India Demand (MW) for Feb 2024

Increasing Ramping Requirement
Resource Adequacy Concerns
Grid Security & Stability
Others

Demand (GW) on 9 Jun 2025





- Typical Ramp rate ~ 250-300 MW/min
- Special Days ~ 500 MW/min

- Duck curve reveals growing midday surplus and evening ramping challenges

All India Generation (Area Plot) 9 June 2025 All India Generation (Area Plot) 31 Dec 2025

Others
Grid Security & Stability
Resource Adequacy Concerns




	Demand	Time	Net Demand	Nuclear	Thermal	Gas	Hydro	Wind	Solar	% RE	Day Peak
Peak (solar hrs)	240	15:30 PM	175	5	149	4	19	19	46	35%	Yes
Peak (non-solar hrs)	238	22:30 PM	217	5	174	8	30	20	0	21%	No

Demand & Generation are in GW. Time is in hh:mm, solar hrs:0600-1800 and non-solar hrs:0000-0600 & 1800-2400


	Demand	Time	Net Demand	Nuclear	Thermal	Gas	Hydro	Wind	Solar	% RE	Day Peak
Peak (solar hrs)	241	10:45 AM	189	6	169	4	12	1	50	26.54%	Yes
Peak (non-solar hrs)	213	18:30 PM	210	5	173	4	27	3	0	14.30%	No

Demand & Generation are in GW. Time is in hh:mm, solar hrs:0600-1800 and non-solar hrs:0000-0600 & 1800-2400

All India Demand Profile on 15 Aug 2025



All India Reserves Profile on 15 Aug 2025



- Need to maximize thermal to meet evening net demand
- Need for thermal to operate at min. level to balance grid during max. RE generation

- Shortfall in down reserves during solar hours
- Shortfall in up reserves during non-solar peak hours

CEA (Grid Standards) Regulations

Others

Regulation 3(C) - Ensure that the temporary over voltage due to sudden load rejection remains within the following limits:

Nominal System Voltage (kV rms)	Phase to Neutral Voltage (kV peak)
765	914
400	514
220	283
132	170

Grid Security & Stability

Maximum fault clearance time is as follows:

Nominal Voltage (kV rms)	Maximum Time (milliseconds)
765 and 400	100
220 and 132	160

Resource Adequacy Concerns


- **Adherence of the regulations shape:**
 - Fault isolation speed.
 - RE ride-through duration.
 - Tolerable voltage stress (avoid cascades)

Increasing Ramping Requirement


A Sample Snapshot

 Date & Location	05-May-2025 Jaisalmer (RJ)
 Initiating event	R–N (phase-to-earth) fault on 220 kV NTPC Solar – Jaisalmer line, reportedly due to snapping at Jaisalmer end
 Protection action / issue	<ul style="list-style-type: none"> ▪ Line fault escalated into a bus fault, leading to operation of 220 kV Bus-2 busbar protection. ▪ R–N fault converted into an R–Y fault, with delayed clearance ~800 ms.
 Impact	Total NR solar generation drop ~1050 MW, of which ~890 MW drop was observed in Rajasthan solar.

Y-o-Y Increasing Penetration of RTS



Y-o-Y Increasing Consumption in EVPCs







- Lack of visibility of RTS generation
- Need of readiness in other emerging areas at distribution downstream – V2G, and BESS


- New EVCI emerging load states - Delhi, Maharashtra, Karnataka, and UP
- EV charging: ~38 TWh by FY2031–32; ~3% of India's annual demand
- Unpredictable charging pattern

The Regional Challenge

Increasing Ramping Requirement | Resource Adequacy Concerns | Grid Security & Stability | Others



Uniform RE obligation construct




High Imports



High landed cost of electricity

Limited need of ESS




Context dependent need of ESS

Increasing DERs



Workforce Development Needs

Way Forward



- 1** Enhance Visibility and Monitoring of Rooftop Solar Generation
- 2** Institutionalize Resource Adequacy Assessments
- 3** Prioritize Distributed Renewable Energy Solutions for Eastern and North-Eastern Regions
- 4** Plan for Grid-Forming Capabilities in High-RE and Weak-Grid Networks

Thanks